



Sanitary Sewer Overflow 5-Day Follow Up Report

Division of Surface Water

Report Submitted By

Date:	7/13/2015
Facility name:	Heatherstone WWTP
Ohio NPDES permit no.:	3PH00054
Period covered by report:	7/9/2015
Contact person	
Name:	Nate Zuege
Title:	Supervisor
Mailing address:	8471 Lakeshore Blvd. Mentor, Ohio
County:	Lake
Telephone:	(440)350 - 3431
Email:	Nate.zuege@lakecountyohio.gov

Signature required at end of form

Overflow Information

Event start date and time – if multiple locations, include information for each	7/9/2015 @ 1:00pm
Event end date and time	7/9/2015 @ 5:00pm
Location(s) the SSO – include unique ID number of one exists	Manhole at the intersection of Madison Avenue and Bowhall Road in Painsville Twp., Ohio
Destination(s) of overflow	<input type="checkbox"/> Basement or building <input checked="" type="checkbox"/> Ground <input type="checkbox"/> Storm sewer to receiving water <input type="checkbox"/> Directly to receiving water
Estimated volume (million gallons) - if multiple locations, include volume for each	.018 MGD
Sewer system component(s) from which release occurred	<input checked="" type="checkbox"/> Manhole <input type="checkbox"/> Constructed overflow <input type="checkbox"/> Pipe crack <input type="checkbox"/> Pump station <input type="checkbox"/> Other (explain)
Cause(s) of overflow	<input checked="" type="checkbox"/> Extreme weather <input type="checkbox"/> Equipment failure <input type="checkbox"/> Power failure <input type="checkbox"/> Debris in line <input type="checkbox"/> Roots <input type="checkbox"/> Grease <input type="checkbox"/> Other blockages <input type="checkbox"/> Line deterioration <input type="checkbox"/> Vandalism <input type="checkbox"/> Other (explain)

Steps taken or planned to eliminate and/or reduce the overflow – include schedule of major milestones	We have conducted flow studies and rehabilitated sewer pipes in this area. We relined the Park Road sewer main in 2011 and continue to monitor this area during rain events.
Steps taken or planned to prevent reoccurrence of the overflow(s) – include schedule of major milestones	When extreme rain events occur, we will dispatch collection system personell to this manhole to monitor and schedule tanker trucks to haul the excessive wastewater.
Steps taken or planned to mitigate the impact(s) of the overflow(s) – include schedule of major milestones	We schedule tanker trucks and private contractors to haul from this area until the flows have receded.
Additional information (attach additional pages, maps, etc. as needed)	


Certification:

I certify that I have personally examined and am familiar with the information in this report and all attachments. I believe that the information is true, accurate, and complete.

Name Nate Zuege
(typed):

Title: Supervisor

Signature:



Date:

7/14/15