



DENK ASSOCIATES, INC.
CONSULTING ENGINEERS

503 EAST 200TH STREET
CLEVELAND OHIO 44119-1574

PH: 216-531-8880
FAX: 216-531-5144

LAKE CTY. BRD. OF COMMISSIONERS – Cooling Tower Replacement Addendum No. 1 – 3/04/10

Prepared For: Lake County Department of Central Purchasing
105 Main Street
Painesville, OH 44077

Title: Lake County Board of Commissioners
Cooling Tower Replacement

Denk Associates, Inc. Project No.: 09202

Prepared By: Denk Associates, Inc.
503 East 200th Street
Cleveland, OH 44119

This Addendum No. 1 supplements and amends the original drawings and specifications and becomes as fully a part of the first issued document as if originally issued or originally contained herein.

Work herein called for shall be performed in the manner described in the original contract documents embracing additions to, deductions from, all changes and substitutions in, or clarifications and emphasis on part of requirements of the drawings and specifications, pertaining to ALL TRADES herewith mentioned for the completion of the PROJECT.

General: Addendum No. 1 is issued this date for the following purposes:

1. Specification Cover Sheet: Change due date to Wednesday, March 10, 2010. Time remains at 11:00 a.m.
2. The Mechanical Contractor will be the lead contractor on the project.
3. Contractor shall review all of the front end documents and Section VI specifications and shall conform to all requirements.
4. Attached is the Pre-Bid Meeting Sign-In sheet.

Drawings: M-1

1. Cooling Tower Specifications: a) add Evapco model LSTB-5212 forced draft cooling tower as an acceptable manufacturer. Adjust existing piping to accommodate unit. b) The cooling tower shall have a five-year warranty.

END OF ADDENDUM
