

LAKE COUNTY BUILDING DEPARTMENT

27 Woodland Road, Painesville, Ohio 44077

TEL: 440-350-2636, 440-918-2636 FAX: 440-350-2660

www.lakecountyohio.gov/buildinginspection

COMMERCIAL FUEL PIPING PRESSURE ACCEPTANCE TEST CERTIFICATE

Test Certification shall be submitted to the Lake County Building Department **PRIOR** to final inspection (OBC 108.8). Any fuel piping systems regulated by the 2011 OMC / 2009 IFGC will require the permit holder to complete this certificate in its entirety.

DATE OF TEST: _____

TIME OF TEST: _____

<u>PROPERTY OWNER / USER</u>	<u>PIPING SYSTEM INSTALLER</u>
Business Name:	Company Name:
Business Address:	Address:
City/State/Zip Code:	City/State/Zip Code:
Owner Contact:	Representative:
Address:	State License #:
Telephone:	Telephone:
<u>TYPE OF FUEL</u> - (NG) (LP) (OTHER) _____	<u>PIPING SYSTEM MATERIAL(S)</u>
Test Medium:	(CHECK ALL THAT APPLY)
Test Pressure:	Steel Schedule 40:
Working Pressure:	CSST:
Number of Fuel Outlets:	Other:
System Volume (IFGC Section 406.4.2):	
Test Duration:	
Leak Test Performed? YES NO	
Piping system is bonded according to the 2009 IFGC Section 310 and if applicable the manufacture's installation requirements? YES NO	

I, hereby certify that the appropriate tests regarding the above system were performed in accordance with the 2009 IFGC Section 406 code requirements and found to be compliant:

Date _____ (Sign Name) _____

(Print Name) _____